

FIRE PANELS

Location	System/Key
Blum Union: Room #121	Simplex 4002, Key #B & Notifier AFP-200, Key #17021
Issues/Concerns: System Normal 12-7-16, System normal	
Spratt Hall: 1st Floor Lobby	Simplex 4002, Key #B
Issues/Concerns: System Normal 12-7-16, System normal.	
Hearnes Center: Room #161	Simplex 4002, Key #B
Issues/Concerns: System Normal 12-7-16, System normal.	
Eder Hall: 1st Floor/Closet under stairway	Notifier SFP-1024, Key #17021
Issues/Concerns: System Normal 12-7-16, System normal.	
Popplewell Hall: Room #112	Simplex 4002, Key #B
Issues/Concerns: System Normal 12-8-16, System normal.	
Murphy Hall: 1st Floor Lobby	Notifier AFP-200, Key #17021
Issues/Concerns: System Trouble, Trouble in Ground Fault, Trouble in Pit & Open Circuit 12-7-16, Panel showed active tamper, PIV in pit zone 4, (no sound coming from panel.)	
Potter Hall: Room #115	Simplex 4002, Key #B
Issues/Concerns: System Trouble & Signal Trouble 12-8-16, System trouble, signal 1 trouble light on.	
Looney Complex: Room #113	Simplex 4002, Key #B
Issues/Concerns: System Trouble & Pull Station 12-8-16, System trouble, pull station, ground trouble lights on.	
Wilson Hall: Room #182	Simplex 4002, Key #B
Issues/Concerns: System Normal 12-13-16, System normal.	
Agenstein Hall/Remington Hall: Room # 118	Notifier NFS-320, Key # 17021
Issues/Concerns: System Trouble, Signal Silenced & Trouble Smoke Duct 12-13-16, System normal.	
Griffon Indoor Sports Complex: Room #100	E3 Series/ Key #IDF PK625
Issues/Concerns: System Trouble Light, Fault Tamper SW, Fault Tamper Vault 12-13-16, System normal.	
Spratt Stadium: Room #106	Simplex 4810/ Key #B
Issues/Concerns: System Normal 12-13-16, Supervisory warning, (no beeping) stairway 2 knox box abnormal, M1-3.	

Conservation Building: Front Lobby, (Main panel in equip. control room, behind front desk area, across from Russ Shiffletts office)	Silent Knight/Key #None
Issues/Concerns: System Normal 12-8-16, All systems normal.	
Kit Bond Building: Main Lobby	Simplex 4010, Key # B
Issues/Concerns: System Normal 12-13-16, All system normal.	
Commons Building: Behind Front Desk	Siemens FS250, Key #T45
Issues/Concerns: System Normal 12-13-16, All systems normal.	
Logan Hall: Room # 102	EST-Quick Start, Key #CAT45
Issues/Concerns: Trouble Light, Ground fault Light, LCL Trouble Panel 101 & Reboot Fault Message. 12-14-16, System normal.	
Beshears Hall: Room # 202	EST-Quick Start, Key #CAT45
Issues/Concerns: Trouble ACK, Panel Silence, Trouble 1st Floor Pull N.E. Stair 12-14-16, 001 trouble 1 st floor pull by NE stairs.	
Juda Hall: Room # 402	EST-Quick Start, Key #CAT45
Issues/Concerns: System Normal 12-14-16, Systems normal	
Leaverton Hall: at Main Door	EST-Quick Start, Key #CAT45
Issues/Concerns: System Normal 12-13-16, All systems normal.	
Vaselakos Hall: at Main Door	EST-Quick Start, Key #CAT45
Issues/Concerns: System Normal 12-13-16, All systems normal.	
Scanlon Hall: at Front Desk	Siemens Fire Finder, Key #T45
Issues/Concerns: System Reset Light, Negative Ground Fault Basement, 1st & 2nd Floors 12-13-16, trouble light on, Electric room 200R, PAD 3 central, (trouble causing input.)	
Griffon Hall: 1 st Floor Lobby	E3 Series/ Key #IDF PK625
Issues/Concerns: System Normal 12-7-16, All systems normal.	

* Baker fitness, (main hall)

Simplex system, -(4002- B key)

Issues/ Concerns: Duct detector, womens restroom, (red light on), yellow light by signal silenced on.

(West Campus, no panel for the area, have smoke detectors and extinguishers.)