



RFP27-017
DATE: 9-28-26
PHONE: (816) 271-4464

ADDENDUM #1

CONCRETE REPAIRS AND SEALING

**SEE BELOW FOR CLARIFICATIONS AND/OR ADDITIONAL INFORMATION.
PLEASE SUBMIT YOUR BID RESPONSE ACCORDINGLY.**

Additional Information to Scope of Work

On page three under Scope of Work where it states, "All areas will be sealed with (2) coats of commercial grade asphalt sealer. Product shall be included in the pricing in Attachment A".

Add the following - "The first coat needs to be applied by squeegee application and the second coat can be spray applied".

Initials _____